

AURANGABAD MUNICIPAL CORPORATION

FIRE BRIGADE

TELEPHONE NO-2334000-40FAX No-2331444

Outward No:AMC/FIRE / 62 /2021

Date 13 / 01 /2021

To,
Shri. Baiyjai Bahuddeshiya Sevabhavi
Shikshan Sanstha, Ujwalatai Pawar School,
Gut No. 108& 109(Pt), Nipani Ta & Dist.
Aurangabad.

Sub:- Provisional Fire NOC is issued to the Shri. Baiyjai Bahuddeshiya Sevabhavi
Shikshan Sanstha, Ujwalatai Pawar School, Gut No. 108& 109(Pt), Nipani Ta &
Dist. Aurangabad.

Ref:- 1) Your letter dated 13/01/2021
2) CFO Inspection on date 13/01/2021

With Reference to the above subject Provisional Fire NOC is issued Shri. Baiyjai
Bahuddeshiya Sevabhavi Shikshan Sanstha, Ujwalatai Pawar School, Gut No. 108& 109(Pt),
Nipani Ta & Dist. Aurangabad. Plot area is 8300.00.00 sq.mtr.

Owner has paid Capition Fees Rs 50,000 /- & Noc fees Rs 20,000/- Total Rs.70,000/- in Fire
brigade Receipt No.117486 dated on 13/01/2021

Sr. No	Name of Building	Height of Building	Bild No.	Floors	Total Area of Plot	Total Buildup area	Fire Fund Fees	Noc Fees Rs.
1	Shikshan Sanstha, Ujwalatai Pawar School Building A	11.92 mtr.	1	B + G+ 2 Floors	8300.00 Sq. mtr	256-17 Sq. mtr	25000/-	10,000/-
2	Shikshan Sanstha, Ujwalatai Pawar School Building B	11.92 mtr.	1	B + G + 2 Floors	8300.00 Sq. mtr	285.58 Sq. mtr	25000/-	10,000/-

Following Fire prevention and Fire protection & Fire Fighting measures subject to Shikshan Sanstha, Ujwalatai Pawar School Building A & B shall be provided.

1. Each building 3.00/4.50 mtr. Open space all around the building shall be provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Each Building Overhead water tank 10000 lit with of suitable capacity for building shall be provided.
3. Each Building Hose reel of 100 feet on all outlets shall be provided.
4. Each Building Fire Escape Staircase 2.00 mtr. Shall be provided.
5. Each Building Fire Extinguisher of ABC / Co2 & Fire Bucket of suitable capacity / quantity shall be provided.
6. Fire alarm System (Detection)/ Manually Call Point / Hooter / Automatic Sprinkler system. Smoke Detector Shall be Provided.
7. All the above requirements shall be carried out with prior approval from fire Brigade.
8. This Certificate shall be treated valid for a period of one year from the date fo issue from Fire Noc.

As per BPMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006. Provisional Fire NOC is issued to the Shri. Baiyjai Bahuddeshiya Sevabhavi Shikshan Sanstha, Ujwalatai Pawar School, Gut No. 108& 109(Pt), Nipani Ta & Dist. Aurangabad.

Chief Fire Officer

Fire Brigade

Municipal Corporation Aurangabad

Copy to:- A D.T.P AMC, Aurangabad.

NOC



औरंगाबाद महानगरपालिका, औरंगाबाद

दुरध्वनी क्र. २३३३७३६-४० फॅक्स क्र. (०२४०) २३३१२१३
अग्निशमन विभाग दुरध्वनी क्र. २३३४०००, फॅक्स क्र. (०२४०) २३३१४४४

क्र.मनपा/अशाद/ 53/ 2029

दिनांक :- १०/०९/२०२१

प्रति,
श्री आनंदा विक्रम सुर्यवंशी,
श्रीमती प्रतिभा आनंदा सुर्यवंशी,
वायजाई बहुउधेशीय सेवाभावी शिक्षण संस्था,
उज्वलाताई पवास हायस्कूल,
गट नं १०८,१०९ मौजे निपाणी
ता जि औरंगाबाद

विषय:- अग्निशमन नः हरकत प्रमाणपत्र दाखत.

संदर्भ:- १. आपले पत्र दिनांक ३१/१२/२०२०

२. मुख्य अग्निशमन अधिकारी याचा अहवाल दि ३१/१२/२०२०


सादर केलेल्या नकाशाप्रमाणे जागेचे क्षेत्रफळ ८३००.०० चौ मी असुन बांधकाम क्षेत्रफळ ३१०७.७५ चौ मी असुन बांधकाम बेसमेन्ट + ग्राउंड + २ मजली असुन इमारत उंची ११.९१ मीटर आहे. बांधकाम खालील प्रमाणे आहे.

१. विल्डींग ए बां. २५६.१७ चौ मी असुन बांधकाम बेसमेन्ट + ग्राउंड + २ मजली असुन इमारत उंची ११.९२ मीटर आहे. फायर फंड रु २५०००/- व एन ओ सी फिस रुपये १०,०००/-
२. विल्डींग ए बां. २८५.५८ चौ मी असुन बांधकाम बेसमेन्ट + ग्राउंड + २ मजली असुन इमारत उंची ११.९२ मीटर आहे. फायर फंड रु २५०००/- व एन ओ सी फिस रुपये १०,०००/-

बांधकाम विकास नियंत्रण नियमावली क्र.६.२.६.१. / ६.५.६.१ अन्वये, महाराष्ट्र फायर प्रिव्हेंशन अॅण्ड लाईफ सेफ्टी मेजर्स अॅक्ट २००६ चे कलम १४ व नियम ११(१) नुसार फायर फंड रुपये ५००००/- व एन ओ सी फिस रुपये २०,०००/- असे एकुण रुपये ७०,०००/- अग्निशमन विभागात जमा करणे आवश्यक आहेत.

अक्षरी:- ७००००/- (सत्तर हजार रुपये फक्त)

करीता अग्निशमन विभागात त्वरीत फिस उप आयुक्त, महानगरपालिका, औरंगाबाद यांचे नावे जमा करणे आवश्यक आहे. म्हणजे ना हरकत प्रमाणपत्र/फायर लायसेन्स वावत पुढील कार्यवाही करणे शक्य होईल. याची नोंद घ्यावी.


मुख्य अग्निशमन अधिकारी,
अग्निशमन विभाग,
महानगरपालिका, औरंगाबाद.